



SPECIFICATION FOR relaying existing p.c. slabs.
 Take up existing p.c. slabs, set them aside, take up existing hardcore and relay with new hardcore to suit new line of paving, lay 600x300x50mm thick p.c. slabs allowing 30% new slabs in a pattern to match existing on 25 mm thick lime and sand (1:3) bedding, slabs grouted in lime and sand (1:2)

SECTION 'A-A'

job no	drawing no									
GLC ILEA										
Department of Architecture and Civic Design County Hall SE1 7PB										
Director of Architecture Peter Jones FRIBA FRTP										
site ref										
drawn			checked			section ref				
telephone 01.633										
revisions										
a - revised										
redrawn										
date										
sept '85										
job										
UPLANDS HOSTEL										
Etheretone Road SW16										
title										
Proposed Ramps										
Blocks C & D										
scale			date							
1:48			Sept 85							
block			storey			section			room	
job no					drawing no					
11221					2a					
(54977) 5-83 AR 100C										